

LAS VEGAS FIRE REGULATIONS

Please find below general guidelines for fire safety. Please refer to the Clark County Department of Building & Fire Prevention website for Requirements and Permit Guidelines, Application Forms, Permit Fees, etc.

Clark County Department of Building & Fire Prevention:

https://www.clarkcountynv.gov/government/departments/building_fire_prevention/index.php

The following items are required to have a permit from the Clark County Department of Building & Fire Prevention:

- Candles and Open Flames (including gelled alcohol, Sterno, etc.)
- Flame Effects
- Open Flame Devices (e.g. candles and gelled alcohol warmers)
- Fireworks/Pyrotechnics
- Compressed Gases
- Cryogenic Fluids
- Hot Works Operations (welding operations)
- Liquid or Gas-Fueled Vehicles or equipment for display in assembly occupancies
- Fire Systems for Covered Booths exceeding 1,000 square feet that will be erected for more than seven (7) show days or contain vehicles, open flame, or hot works.
- Tents and/or Canopies
- Temporary Membrane Structures
- Temporary Outdoor Structures

PLEASE NOTE: Failure to notify show management and/or apply for permit no later than three weeks prior to the move-in of an event could result in higher permit fees or non-admission of the item/service to the exhibit floor.

- 1. In accordance with the Nevada Clean Indoor Air Act, smoking is prohibited in exhibit areas.**
- 2. All materials used in construction and decoration of an exhibit must be flame retardant.** Fabrics must be certified as flame retardant or a sample must be available for testing. Materials which cannot be treated to meet the requirements may not be used. NFPA 701 is the accepted standard.
- 3. All exits and exit aisles must be kept clear and unobstructed.** No furniture, signs, easels, chairs or displays may protrude into aisles unless shown on the Fire Marshal approved floor plan.
- 4. Designated "No Freight" aisles must be maintained clear of crates and exhibit materials during move-in and move-out.** These aisles are required for emergency access throughout the hall and to expedite freight and empty crate moving.
- 5. All empty cartons or crates must be labeled and removed for storage or they will be removed as trash.** Crates are not to be used as exhibit supports.
- 6. All fire hose racks, fire extinguishers, strobe lights and emergency exits must be visible and accessible (3' clearance for hoses and extinguishers) at all times.** This includes fire protection equipment located within exhibits. Exits and exit signs must not be covered by drapes nor obscured from view by exhibit components.
- 7. Exhibitors who intend to display a vehicle within the confines of their exhibit booth must obtain a vehicle display permit from the Clark County Department of Building & Fire Prevention.** At least one battery cable shall be removed from the battery used to start the engine. (Batteries for auxiliary equipment may be connected.) The fuel tank shall not have more than 1/4 capacity or five (5) gallons, whichever is less. Fuel tank(s) are sealed. Fueling or de-fueling is not permitted in the assembly occupancy. A 36" wide access aisle or clear space is maintained around all sides of the display and a minimum of 20 feet away from exit doors, exit stairs, the exit access or exit passageways. No leaks of fluids. No relocation of the display during exhibit hours.
- 8. Combustible materials must not be stored beneath display vehicles.** Space beneath vehicles must be clear and visible except for permitted electrical supplies.
- 9. Vehicles in building for unloading must not be left with engine idling.** Exhaust gases present extreme hazards to workers on catwalks. If engine cannot be shut down, vehicle must be removed from the building as quickly as possible.
- 10. No storage of any kind is allowed behind booths or near electrical service.** Materials for hand-outs must be limited to one day supply and stored neatly within the booth. Violators will be notified and if not removed by show opening, Official Service Contractor will remove and store at **EXHIBITOR'S EXPENSE.**

LAS VEGAS FIRE REGULATIONS (continued)

11. **All 110 volt extension cords shall be three-wire (grounded), #14 or larger AWG, copper wire. All connections must be supported and secure.** Two wire, "Zip Cords" are not permitted other than factory installed appliance connectors; these may not exceed six (6) feet in length and must be UL approved.
12. **Cube tap adapters are prohibited (Uniform Fire Code 85.107). Multi-plug connectors must be UL approved with built-in overload protection.** Connectors must not be used to exceed their listed ampere rating.
13. **Electrical work under carpets or flooring must be installed by the official electrical service provider.** All cords must be flat, three conductor, #14 AWG or larger.
14. **All temporary wiring must be accessible and free from debris and storage materials.** Hard backed booths must have power supplies dropped within the booth.
15. **Compressed gas cylinders, including LPG, must obtain a permit from the Clark County Department of Building & Fire Prevention.** Flammable gases, i.e.: butane, propane, natural gas, et al; are subject to prior approval. Non-flammable compressed gas cylinders must be secured in an upright position with gauges and regulator protected against physical damage.

Exception: Please contact the Las Vegas Convention Center for their specific guidelines.

16. **Certain halogen lamps have been banned at the Las Vegas Convention Center, Mandalay Bay Convention Center, The Venetian Expo, and Cashman Center.**
17. **Single-level covered exhibits require automatic fire sprinklers underneath covered areas greater than 1,000 square feet that will be in place for 7 or more show days (not including move-in and move-out days).** Sprinklers are also required when there will be vehicles, open flame, or hot works underneath any covered areas. The permit that is required is only for the installation of fire sprinklers, not for structural review of exhibits.

Exception: Where the booth is used in an event with duration less than 7 calendar days and does not contain vehicles, open flame or hot works, automatic fire sprinklers are not required, provided the aggregate area of unsprinklered booths within the room does not exceed 30% of the room size.

18. **Please note: These are Clark County Department of Building & Fire Prevention guidelines. Please contact the the event facility for specific guidelines.**

Multi-level covered exhibits require automatic fire sprinklers underneath all covered areas on each level when the walking surface of the upper level(s) is over 1,000 square feet that will be in place for 7 or more show days (not including move-in and move-out days). Upper level areas of multi-level exhibit booths exceeding 300 square feet shall not have less than two remote means of egress. Sprinklers are also required when there will be vehicles, open flame, or hot works underneath any covered areas. The permit that is required is only for the installation of fire sprinklers, not for structural review of exhibits. Any exhibit with an upper deck area to be occupied must be evaluated and stamped by a licensed engineer. The upper level of multi-level exhibit booths exceeding 300 square feet shall have not less than two remote means of egress. Stamped plans should be present within the exhibit for potential verification by the Fire Marshal upon request.

Exception: Where the booth is used in an event with duration less than 7 calendar days and does not contain vehicles, open flame or hot works, automatic fire sprinklers are not required, provided the aggregate area of unsprinklered booths within the room does not exceed 30% of the room size.

19. **Tents in excess of 400 square feet, canopies in excess of 700 square feet, and temporary membrane structures must be approved by the Clark County Department of Building & Fire Prevention.**
20. **Demonstration cooking and food warming in exhibition spaces shall comply with the Clark County Fire Code and facility regulations.**
21. **The use of candles and other open flame decorative devices must be approved by the Clark County Department of Building & Fire Prevention.**